

GLSA-ODT/OIR-FP-500

Occupancy Sensor Lens, 500 Sq. Ft. Installation Guide




Installation


NOTE: If using on a GLS-ODT-C-CN or GLS-ODT-C-NS sensor, disable the ultrasonic motion transducers. Refer to the GLS-ODT-C-CN Guide (Doc. 7427), GLS-ODT-C-NS Guide (Doc. 7428), or GLS-REMOTE-ODT/OIR Guide (Doc. 7541) at www.crestron.com/manuals for more information.

Install the Crestron® occupancy sensor lens.

1. Turn the occupancy sensor cover counterclockwise, and then remove it from the device.



2. Place the GLSA-ODT/OIR-FP-500 occupancy sensor cover on the device and then rotate the cover clockwise to secure it to the device.



Additional Resources

Visit the product page on the Crestron website (www.crestron.com) for additional information and the latest firmware updates. Use a QR reader application on your mobile device to scan the QR image.



As of the date of manufacture, the device has been tested and found to comply with specifications for CE marking.



Product warranty can be found at www.crestron.com/warranty.

The specific patents that cover Crestron products are listed at patents.crestron.com.

Certain Crestron products contain open source software. For specific information, please visit www.crestron.com/opensource.

Crestron and the Crestron logo are either trademarks or registered trademarks of Crestron Electronics, Inc. in the United States and/or other countries. Other trademarks, registered trademarks, and trade names may be used in this document to refer to either the entities claiming the marks and names or their products. Crestron disclaims any proprietary interest in

the marks and names of others. Crestron is not responsible for errors in typography or photography.

This document was written by the Technical Publications department at Crestron.

©2016 Crestron Electronics, Inc.

Crestron Electronics, Inc.

15 Volvo Drive Rockleigh, NJ 07647

Tel: 888.CRESTRON

Fax: 201.767.7576

www.crestron.com

Installation Guide - DOC. 7746A

(2043192)

05.16

Specifications subject to
change without notice.