

Summary of Crestron MP2 architectural specifications are as follows.
Minimum control system requirements:

- Control System shall utilize a Motorola Coldfire processor at no less than 257 MIPS.
- Control System shall include [2] RS-232/422/485 Ports.
- Control System shall include [4] IR/Serial Ports.
- Control System shall include [4] Isolated Relay Ports
- Control System shall include [4] I/O Ports.
- Control System shall include [1] IR Receiver Port for optional IR-Receiver, which is compatible with Universal IR-Remotes that transmit standard RC-5 Codes.
- Control System shall include [1] Cresnet Port.
- Control System shall include a built-in [4 x 2] Video Switch – (Composite; which can also be configured as [2 x 1] S-Video).
- Control System shall include a built-in [7 x 1] Stereo Audio Switch and built-in Volume, Bass, Treble Control for all channels.
- Control System shall include a built-in 6-Band Parametric Equalizer, configurable using Crestron Digital Audio Tools Software. Digital Audio Tools Software shall support auto configuration/programming of multiple custom preset Parametric and Graphic Equalization modes.
- Control System shall include built-in Video Sync-Sensors on all Video-Inputs for Source Device Status Sensing.
- Control System shall be able to be automatically configured and programmed using Crestron MP2 System-Builder Software. System Builder Software shall not require any prior/formal programmer training, and shall support IR/Serial/RS-232 Drivers for thousands of Industry standard devices.
- Control System Processor shall utilize a real time, event driven, multi-tasking, multi-threaded operating system.
- High speed processor shall communicate directly with control ports and proprietary control network utilizing high-speed, parallel bus infrastructure. Control processors that communicate via a serial bus shall not be accepted.
- Control processor shall contain 36 MB of memory.
- Control System processor shall utilize a FAT32 file structure.
- Patent pending Network Analyzer to continuously monitor the integrity of the Cresnet network for wiring faults, marginal communication performance, network errors – all information is viewable.
- Support RS-485 token passing network with data communication for a minimum distance of 5000 feet.
- Allow proprietary network expansion via RS-232 ports, which can allow for high-speed network acceleration.
- Support a minimum of 253 proprietary network devices simultaneously.

- Control system shall support object-oriented logic based programming language and a C-like language programming language. Both programming types are supported to run simultaneously and integral to each other.
- Control system manufacture shall supply Windows-based graphical programming software for drag and drop object oriented programming for the control system operation.
- Control system manufacture shall provide Windows-based graphical programming software, which is self-documenting in that it generates a symbolic flow diagram printout from the system program.
- The control system shall support a variety of wireless communication modes, including one-way and two-way radio frequency and infrared transmission.